

Pinellas Suncoast Fire & Rescue

304 1st St., Indian Rocks Beach, Florida 33785 727-595-1117 lifesafety@psfrd.org

Short-Term Rental Pre-Inspection Checklist Multi-Family

| BUILDING AND PREMISE | \checkmark |
|---|--------------|
| Address posted and visible (4"-6" in height) | |
| Grills, smokers, heaters, etc., used more than 10' from any structure | |
| Storage of materials neat and orderly | |
| Storage around water heater greater than 12" (If possible) | |
| EXITS | \checkmark |
| Stairs have one (1) graspable handrail | |
| No storage of flammable/combustibles on, in or under exits or escape paths | |
| Stairs, landings, exit paths clear of trip hazards Recommended minimum width of 36'' | |
| Exit/Escapes require no key or tool from inside to open | |
| ALERTING AND EVACUATION | \checkmark |
| Hardwired smoke detectors installed per Florida Building Code R314 | |
| Smoke detectors available for the deaf or hearing impaired | |
| Carbon Monoxide detectors installed in locations with garage and/or gas appliances | |
| Evacuation plan created and posted in a conspicuous location identifying exits and | |
| procedures for reporting emergencies | |
| ELECTRICAL SAFETY | ✓ |
| No open spaces in break/fuse box | |
| All breakers and fuses are labeled | |
| No exposed electrical wiring | |
| No extension cords/multiplug adapters in use (Utilize fused power strips) | |
| All appliances plugged directly into outlet | |
| PROTECTION | \checkmark |
| ABC fire extinguisher present and clearly visible on each level (Requires annual inspection tag from licensed provider) | |
| Fire Extinguisher mounted no more than 5' high or 4" from the ground | |
| Dryer properly vented and clear of lint | |
| LP/Gas Tanks not stored indoors and in good working order | |